

A NEW TUNING METHOD FOR PID CONTROLLERS

D. Vrančić, Y. Peng^{*}, J. Petrovčič, and R. Hanus^{*}

*Department of Computer Automation and Control
J. Stefan Institute, Jamova 39, SI-1001 Ljubljana, Slovenia
e-mail: damir.vrancic@ijs.si, FAX: +386-61-219-385, phone: +386-61-1773-732*

^{}Department of Control Engineering
Free University of Brussels, Av. Franklin D. Roosevelt, 50, B-1050, Brussels, Belgium
e-mail: peng@labauto.ulb.ac.be, FAX: +32-2-650-26-77, phone: +32-2-650-26-86*

Abstract: In this paper a new tuning approach for the PID controllers is proposed. The tuning algorithm is based on a relatively demanding magnitude optimum criterion. However, the tuning procedure is simple and only requires a process open-loop step response in order to calculate controller parameters. Additional relay excitation may be provided so as to obtain more optimal values of the PID controller parameters.

Keywords: PI controllers, PID controllers, Self-tuning regulators, Moment method, Windup